

Okonite Cables

Facilities Overview

District Offices, Manufacturing Plants & Service Centers

Manufacturing Plants



Orangeburg, SC - Compound Facility



Orangeburg, SC - Manufacturing Plant



Richmond, KY - Manufacturing Plant



Santa Maria, CA - Manufacturing Plant



Cumberland, RI - Manufacturing Plant



Paterson, NJ - Manufacturing Plant

Atlanta District Office
(770) 928-9778
FAX: (770) 928-0913
E-Mail: atlanta@okonite.com

Birmingham District Office
(205) 655-0390
FAX: (205) 655-0393
E-Mail: birmingham@okonite.com

Boston District Office
(603) 625-1900
(781) 749-3374
FAX: (603) 624-2252
E-Mail: boston@okonite.com

Charlotte District Office
(704) 542-1572
FAX: (704) 541-6183
E-Mail: charlotte@okonite.com

Chicago District Office
(630) 961-3100
FAX: (630) 961-3273
E-Mail: chicago@okonite.com

Cincinnati District Office
(513) 771-2122
FAX: (513) 771-2126
E-Mail: cincinnati@okonite.com

Cleveland District Office
(330) 926-9181
FAX: (330) 926-9183
E-Mail: cleveland@okonite.com

Dallas District Office
(940) 383-1967
FAX: (940) 383-8447
E-Mail: dallas@okonite.com

Denver District Office
(303) 772-3517
FAX: (303) 255-3513
E-Mail: denver@okonite.com

Hartford District Office
(860) 258-1900
FAX: (860) 258-1903
E-Mail: hartford@okonite.com

Houston District Office & Service Center
(281) 821-5500
FAX: (281) 821-7855
E-Mail: houston@okonite.com

Kansas City District Office & Service Center
(913) 422-6958
FAX: (913) 422-1647
E-Mail: kansascity@okonite.com

Los Angeles District Office
(562) 590-3070
Fax: (562) 590-3139
E-Mail: losangeles@okonite.com

Minneapolis District Office
(763) 432-3818
FAX: (763) 432-3811
E-Mail: minneapolis@okonite.com

New Orleans District Office and Service Center
(504) 467-1920
FAX: (504) 467-1926
E-Mail: neworleans@okonite.com

New York District Office
NJ (973) 742-8040
NY (212) 239-0660
FAX: (973) 742-2156
E-Mail: newyork@okonite.com

Philadelphia District Office
(856) 931-0595
(215) 567-5739
FAX: (856) 931-1193
E-Mail: philadelphia@okonite.com

Phoenix District Office
(480) 838-8596
FAX: (480) 897-8924
E-Mail: phoenix@okonite.com

Pittsburgh Service Center
(724) 899-4300
FAX: (724) 899-4320
E-Mail: pittsburgh@okonite.com

Portland District Office & Service Center
(503) 598-0598
FAX: (503) 620-7447
E-Mail: portland@okonite.com

Salt Lake District Office
(801) 262-1993
FAX: (801) 262-3167
E-Mail: saltlake@okonite.com

San Francisco District Office
(925) 830-0801
FAX: (925) 830-0954
E-Mail: sanfrancisco@okonite.com

Tampa District Office
(813) 627-9400
FAX: (813) 246-4705
E-Mail: tampa@okonite.com

Washington District Office
(703) 904-9494
FAX: (703) 904-1610
E-Mail: washington@okonite.com

International Sales
(201) 825-0300
FAX: (201) 825-9026
E-Mail: ramsey@okonite.com

Service Centers



Houston, TX



Kansas City, KS



New Orleans, LA



Portland, OR



Pittsburgh, PA

Corporate HDQ



Ramsey, NJ

OKONITE

SUBSTATION CONTROL CABLES



THE OKONITE COMPANY

102 Hilltop Road, Ramsey, NJ 07446 • 201.825.0300 Fax: 201.825.9026 • www.okonite.com

Printed on post consumer paper

05684



THE OKONITE COMPANY

Setting the Standard in Quality Since 1878

Okonite 12/2015

APPLICATION

Utility substation control cables are multiconductor cables used to transmit low voltage and low current signals between the various electrical components (e. g. current transformers, relays, alarms, and monitoring equipment) in a substation. The signals can be analog or digital, continuous or intermittent.

Substation control cables are generally terminated in cabinets and the utilization equipment. They are often installed in cable trays, wireways, conduits, duct banks & trenches. These cables are suitable for wet or dry locations. Ambients are typically assumed to be 40°C air and 20°C earth.

Substation control cables can be rated 90°C or 75°C for wet and dry applications. Most substation cables have a -25°C installation temperature, but cables can be designed for -40°C installation applications, also.

Substation control cables can be shielded or unshielded. Shielded cables are used when shielding from ambient electrical interference is required. Typically shielded control cables are utilized in 230kV and above substations or, at lower voltages, where requirements dictate the need. High voltage transients could cause erroneous operation of or damage to equipment. Properly grounded shields help mitigate these types of occurrences.

The lower the shield resistance the more effective the shielding. Shields are typically a helically applied overlapped copper tape or a longitudinally applied overlapped copper tape. Sometimes the tape is supplemented with a bare copper grounding conductor.

Depending upon how these cables are installed, substation control cables are often required to pass a vertical tray flame test.



Contact your Okonite Sales Rep. who can assist you along with our staff of Application Engineers.



INDUSTRY STANDARDS

Okonite can manufacture cables to the following industry standards:

- ICEA S-73-532/NEMA WC57: Standard for control cables.
- ICEA S-95-658/NEMA WC70: Standard for power cables rated 2000V or less for distribution of electrical energy.
- UL 1277: Standard for electrical power and control tray cables with optional fiber members.

FLAME TEST RATINGS

The following flame test ratings can be provided on Okonite substation cables:

- IEEE 383-74
- IEEE 1202

CABLE DESIGN CONSIDERATIONS

- Conductor: Bare or tinned copper stranded conductors, Class B or C
- Insulation Color Code: ICEA methods 1 to 4.
- Grounding Conductor.
- Insulation: EPR, XLPE, PE/PVC.
- Voltage Ratings: 600V – 1000V.
- Shielding: Helically applied copper tape, longitudinal corrugated copper tape, bare or tinned.
- Jacket Rip Cord.
- Overall Jacket: PVC, FR PVC, TP-CPE, TS-CPE, LSZH (TPPO, XLPO).

